



TOWN OF WINDERMERE
614 MAIN STREET
WINDERMERE, FLORIDA 34786
PHONE: (407) 876-2563
FAX: (407) 876-0103

ADDENDUM NO. 3

BID NO. 2017-05 – FIRST AVENUE AND FOREST STREET DRAINAGE IMPROVEMENTS

January 11, 2018

To All Bidders:

This Addendum becomes hereby an integral part of the bid package under consideration by you as a respondent. The Town of Windermere deems all sealed bids to have been proffered in recognition of the entire bid package, including all issued Addenda.

This Addendum is being posted on the Town's Website and other procurement sources and also sent to any Vendor via fax or e-mail, if so requested. Should you have any questions pertaining to this Addendum, please contact Michael Galura, P.E. at (407) 493-9983 or by e-mail at: mchgalu@aol.com.

ADDENDUM MESSAGE

The following clarifications and/or changes become hereby a part of this bid and shall be included in the Contractor's Bid Prices:

The following are responses to questions received by the Town:

1. Sheet 16 of 47 – the plan view indicated 30" French Drain. The drainage cross-sections and profile indicate 24". Please confirm that this is correct.

The plan view label for "30" FRENCH DRAIN" is incorrect. All French drains should be 24" for the entire plan set.

Issued By: *Michael B. Galura*

Michael B. Galura, P.E.
Michael Galura Engineering Consultants
3222 Corrine Drive, Suite H
Orlando, FL 32803
Phone: (407) 493-9983
E-Mail: mchgalu@aol.com
<http://www.mgaluraengineeringconsult.com>